

John Grinham

438 2528 (W)

411 4687 (H)


7 July 1992

*Basil*  
Dear David,

Ernie has asked me to convey to you the details of the thermostat controls to the heating system.

It is quite simple. The thermostat is fixed to the kitchen wall facing the dining area. At the moment it is set to a frost protection setting; this activates the heating when the room temperature falls to 5 degrees celsius. To get it back to its normal setting press the button marked "2" on the attached sheet until the black dot moves to  $\odot$  1.7

The normal setting runs as follows; the times and temperatures may vary slightly from what is shown:



When you first go in the lodge will be cold; if you wish to keep the heating on full during a down period when the temperature is set at 15 degrees just press the over-ride button (marked "3" on the attached sheet). I am not sure, however, what happens next. The attached sheet states that "when the interposed period elapses the originally entered switching programme takes over." My hand written notes state the opposite - "the over-ride button must be pressed again at the end of the interposed period in order to resume normal operations." Perhaps we should assume that my notes are wrong and that the printed instructions are correct. I have been wrong before (or have I?).

As an alternative to the over-ride button I believe that you could switch the mode of operation to \*T3 until the lodge has achieved normal temperature. I must apologise if I appear to be vague but I haven't used it for 2 years.

If you have any problems please call me. Apart from anything else I would appreciate some feedback.

I hope you are keeping well - regards to Chrissie. And don't even think about thinking about work while you are away - it is forbidden.

Regards,